

CERTIFICATE OF COMPLIANCE

Certificate Number 20180529-EX15268
Report Reference EX2534-19880919
Issue Date 2018-MAY-29

Issued to: CLA-VAL CANADA CORP
4687 CHRISTIE DR
BEAMSVILLE
ON L0R 1B4 CANADA

**This is to certify that
representative samples of**

SPECIAL SYSTEM WATER CONTROL VALVES, CLASS II
Pilot-operated pressure-control valves are intended to
reduce the water pressure in the supply piping for standpipe
systems for fire protection service
90G-21, 90A-21

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.

Standard(s) for Safety: UL1739 - Pilot-Operated Pressure-Control Valves for Fire-
Protection Service

Additional Information: See the UL Online Certifications Directory at
www.ul.com/database for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's
Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please
contact a local UL Customer Service Representative at <http://ul.com/about/locations/>

