MODULATING FLOAT CONTROL VALVE

INTRODUCTION

This specification covers the design, manufacture, and testing of 2 in. (50 mm) through 36 in. (900 mm) Control Valves

PART 1 - GENERAL

- 1. Standard products use the same manufacturer for multiple units of same type.
- 2. "Tying" of equipment into packages for the purpose of thwarting competition shall be considered to be in non-compliance with these specifications.
- 3. Manufacturers shall price items under different subsections or sections separately.

PART 2 - PRODUCTS

2.01 MODULATING FLOAT CONTROL VALVES

A. FUNCTION

The Modulating Float Valve shall modulate to maintain a constant liquid level in a storage tank by compensating for variations in supply or demand. The valves float pilot control system shall be sensitive to slight changes in liquid level, immediately controlling the main valve and maintaining the desired liquid level in the storage tank. Valve shall be capable of controlling the flow either into or out of the storage tank. Valve shall be capable of modulating closed on rising level or modulating open on rising level.

B. MATERIALS

1. Material Specification for the Float Control Valves Main Valve as follows:

A536	
ze (optional)	
ailable (optional)	
anabic (optional)	
ailable (optional)	
Buna-N® Rubber	
Buna-N® Rubber	
ailable (optional)	
onze; Brass	
5")	
6")	
Class 150 lb. (250psi Max.)	
osi Max.)	

Temperature Range Water to 180°F

Any other wetted metallic parts

Stainless Steel; Bronze; Brass

Coating Fusion Bonded Epoxy Coating (Interior and Exterior);

ANSI / NSF 61 Approved /

AWWA coating specifications C116-03.

C. MANUFACTURE

1. Main Valve:

a. The main valve shall be hydraulically operated, single diaphragm actuated, globe or angle pattern. The valve shall consist of three major components; the body with seat installed, the cover with bearing installed and the diaphragm assembly. The diaphragm assembly shall be the only moving part and shall form a sealed chamber in the upper portion of the valve, separating the operating pressure from line pressure. Packing glands, stuffing boxes and/or rolling diaphragm technology will not be permitted and there shall be no pistons operating the main valve or pilot controls. No fabrication or welding shall be used in the manufacturing process. Y-pattern valves shall not be permitted. Main valve shall comply with NSF/ANSI Standard 61 and certified lead free to NSF/ANSI 372 as a safe drinking water system component.

2. Main Valve End Connections:

a. End Connections for control valve shall be flanged per ASME/ANSI B16.42, Class 150 or Class 300 (2" thru 6") or Threaded End Connections (1" thru 3") or Grooved End Connections (2" thru 6").

3. Main Valve Body:

- a. No separate chamber(s) below the diaphragm shall be allowed between the main valve cover and body. No fabrication or welding shall be used in the manufacturing process.
- b. The valve shall contain a resilient, synthetic rubber disc with a rectangular cross-section contained on three and one half sides by a disc retainer and forming a tight seal against a single removable seat insert. No O-ring type discs (circular, square, or quad type) shall be permitted as the seating surface. The disc guide shall be of the contoured type to permit smooth transition of flow and shall hold the discs firmly in place. The disc retainer shall be of a sturdy one-piece design capable of withstanding opening and closing shocks. It must have straight edge sides and a radius at the top edge to prevent excessive diaphragm wear as the diaphragm flexes across this surface. No hours-glass shaped disc retainers shall be permitted and no V-type or slotted-type disc guides shall be used.
- c. The diaphragm assembly containing a non-magnetic 303 stainless steel slotted stem assembly; of sufficient diameter to withstand high hydraulic pressures and shall be fully guided at both ends by a bearing in the main valve cover and an integral bearing in the valve seat. The valve seat shall be a solid, one-piece design and shall have a minimum five-degree taper on the seating surface for a positive, drip-tight shut off. No center guides shall be permitted. The diaphragm assembly shall be the only moving part and shall form a sealed chamber in the upper portion of the valve, separating the operating pressure from the line pressure. No bolts or cap screws shall be permitted for use in the construction of the diaphragm assembly.
- d. The flexible, non-wicking, FDA approved diaphragm shall consist of nylon fabric bonded with synthetic rubber compatible with the operating fluid. The diaphragm's center hole for the main valve stem must be sealed by the vulcanized process or a rubber grommet sealing the center stem hole from the operating pressure. The diaphragm must withstand a Mullins Burst Test of a minimum of 600 X per layer of nylon fabric and shall be cycled tested 100,000 times to insure longevity. The diaphragm shall not be used as the seating surface. The diaphragm shall be fully supported in the valve body and cover by machined surfaces which support no less than one-half of the total surface area of the diaphragm in either the fully opened or fully closed position. Bellofram type rolling diaphragms shall not be permitted.
- e. The main valve seat and stem bearing in the valve cover shall be removable. The cover bearing and seat in the 6" and smaller size valve shall be threaded into the cover and body. The lower bearing of the valve stem shall be contained concentrically within the seat and shall

be exposed to the flow on all sides to avoid deposits. To insure proper alignment of the valve stem, the valve body and cover shall be machined with a locating lip. No "pinned" covers to the valve body shall be permitted. Cover bearing, disc guide and seat shall be made of the same material. All necessary repairs and/or modifications other than replacement of the main valve body shall be possible without removing the valve from the pipeline. The valve shall be designed such that both the cover assembly and internal diaphragm assembly can be disassembled and lifted vertically straight up from the top of a narrow opening/vault. Y-pattern valves shall not be permitted. The seat shall be of the solid one piece design. Two piece seats or seat inserts shall not be permitted. Packing glands and/or stuffing boxes shall not be permitted.

4. Pilot Control System:

- a. The Pilot Control System shall consist of a Variable Orifice proportioning Pilot Control mounted on the valve cover, and a Remote Mounted Float Control. The float control pilot shall be a rotary disc, plate-type that varies the pressure in the main valve cover, causing it to seek a new position. A slight change in liquid level moves the float control; immediately controlling the main valve, maintaining the desired liquid level in the storage tank. The Variable Orifice Pilot tracks the main valve movement, automatically regulating the flow into the cover until the valve attains a position that is in direct relation to the position of the float control. Float control pilot shall include a minimum 24" (.60 m) vertical float rod with two adjustable stops. Pilot shall comply with NSF/ANSI 61 and certified lead free to NSF/ANSI 372 as a safe drinking water system component.
- b. The pilot control system shall include a strainer and all required control accessories, equipment, control tubing and fittings. Pilot to be manufactured by control valve manufacturer.

5. Material Specification for Float Control Pilot:

<u>Component</u> <u>Material</u>
Body / Base Bronze

Pilot Trim Nylon Reinforced Delrin®, Stainless Steel, Monel

Seat / Stem Stainless Steel 303 Float Stainless Steel 304

Other Materials Available (optional)

Float Linkage Brass and PVC

Float Rod (24") PVC

Other Materials Available (optional) Extensions Available (optional)

Base Plate Stainless Steel 316

Rubber Buna-N
Connections FNPT
Pressure Rating 150 psi Max.

Temperature Range Water to 160°F Max.

Control Tubing Copper

Stainless Steel (optional)

Flexible Braided Stainless Steel (optional)

Polyethylene (optional)

Control Fittings Brass

Stainless Steel (optional)

6. Factory Assembly:

- a. Each control valve shall be factory assembled.
- The Quality Management System of the factory shall be certified in accordance with ISO 9001: 2008.
- c. For all control valves, the factory assembly shall include the complete main valve, pilot valve(s), and all associated accessories and control equipment.

d. During factory assembly the control valve manufacture shall make all necessary adjustments and correct any defects.

7. Nameplates:

- a. Each Control Valve and associated pilot(s) shall be provided with an identifying nameplate.
- b. Nameplates, depending on type and size of control valve, shall be mounted in the most practical position possible, typically on the inlet side of the valve body.
- c. Nameplates shall be brass and a minimum of 3/32" thick, 3/4" high and 2-3/4" long.
- d. Pertinent control valve data shall be etched or stamped into the nameplate. Data shall include control valve Catalog number, function, size, material, pressure rating, end-connection details, type of pilot controls used and control adjustment range.

8. Factory Testing:

- a. Each control valve shall be factory tested.
- b. The Quality Management System of the factory shall be certified in accordance with ISO 9001: 2008
- c. Tests shall conform to approved test procedures.
- d. The standard factory tests shall include a valve body and cover leakage test, seat leakage test and a stroke test. Control valves and pilot valves, in the partially open position, with both ends closed off with blind flanges (valves) and pipe plugs (pilots), shall be subject to an air test. The applied air pressure shall be 90 psi minimum. All air pressure tests shall be applied for a minimum of 15 minutes. No visible leakage is permitted through the valve seat, the pressure boundary walls of the valve body, valve cover, pilot body, pilot cover or the body-cover joint.
- e. Control valve manufacturer shall, upon request, offer additional testing, such as high pressure hydrostatic testing, positive material inspection testing, ferrite testing, liquid penetration inspection testing, magnetic particle examination testing and radiographic examination testing.

D. PRODUCT DATA

- 1. The following information shall be provided:
 - a. Control Valve manufacturer's technical product data.
 - b. Control Valve manufacturer's Installation, Operation and Maintenance manual (IOM).
- 2. Provide specific information on all optional features specified above and confirm that these items are provided.
- 3. The valve manufacturer shall be able to supply a complete line of equipment from 1/2" through 8" sizes and a complete selection of complementary accessories and equipment.
- 4. The control valve manufacture shall provide a computerized cavitation analysis report which shows flow rate, differential pressure, and percentage of valve opening. Cv factor, system velocity, and if there will be cavitation damage.

PART 3 - EXECUTION

A. DELIVERY, STORAGE AND HANDLING

1. Delivery

a. The Manufacture shall deliver the control valves to:

Address, City, State, Zip. Attention: Phone number: Call 48 hours prior to delivery.

b. Upon delivery, control valves to be unloaded and stored by the

Owner, district or municipality.

1. Packing and Shipping

- a. Control valves specified herein shall be factory assembled. Any control valve appurtenances, accessories, parts and assemblies that are shipped unassembled shall be packaged and tagged in a manner that will protect the equipment from damage and facilitate the final assembly in the field.
- b. Care shall be taken in loading, transporting and unloading to protect control valves, appurtenances, or coatings from damage. Equipment shall not be dropped. All control valves and appurtenances shall be examined before installation and no piece shall be installed which is found to be defective. Any damage(s) shall be repaired.
- c. Prior to shipping, the control valves and all associated accessories shall be acceptably packaged and covered to prevent entry of foreign material.
- a. All packaged control valves shall be shipped, remain covered and stored on site until they are installed and put into use.

B. FIELD TESTING

1. A direct factory representative shall be made available by the equipment supplier for start-up service, inspection and necessary adjustments.

The Control Valve manufacturer shall warrant the valve to be free of defects in material and workmanship for a period of three years from date of shipment provided the valve is installed and used in accordance with all applicable instructions. Electrical components shall have a one-year warranty.

The control valve shall be a **Cla-Val Company Model No. 427-01**, Modulating Float Control Valve, as manufactured by Cla-Val Co., Newport Beach, CA 92659-0325.

END OF SECTION