



## Certified Product Listing

**For:**

Drinking Water System Components - Health Effects

**Company:**

CLA-VAL  
1701 Placentia Avenue  
Costa Mesa, CA 92627, United States

**Plant Location:**

Costa Mesa, CA, United States

**Standards:**

NSF/ANSI/CAN 61 - 2020  
NSF/ANSI/CAN 372 - 2020

**Certificate:**

Issued Date: 08/10/2018

**Material/Product:**

Air Release & Vacuum Breaker - Water Service

**Contact Temperature:**

82 ± 2°C

**Models:**

33A  
33ATD  
33AWS

Sizes 1", 2", 3", 4", 6"