

CERTIFICATE OF COMPLIANCE

Certificate Number UL-US-L26932-111-52806102-1
Report Reference EX26932-20160825
Date 2023-SEPTEMBER-18

Issued to: GRISWOLD INDUSTRIES, DBA CLA-VAL CO
1701 PLACENTIA AVE COSTA MESA, CA 92627-4416
United States

This is to certify that QWBS - Air-release Valves for Fire Pumps
representative samples of See Addendum Page for Product Designation(s).

Have been evaluated by UL in accordance with the
Standard(s) indicated on this Certificate.


Standard(s) for Safety: UL 2573 – Outline of Investigation for Automatic Air
Release and Air/Vacuum Valves for Fire Protection Service

Additional Information: See the UL Online Certifications Directory at
<https://iq.ulprospector.com> for additional information

This Certificate of Compliance indicates that representative samples of the product described in the certification report have met the requirements for UL certification. It does not provide authorization to apply the UL Mark. Only the Authorization Page that references the Follow-Up Services Procedure for ongoing surveillance provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.


Deborah Jennings-Conner, VP Regulatory Services

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



CERTIFICATE OF COMPLIANCE

Certificate Number UL-US-L26932-111-52806102-1
Report Reference EX26932-20160825
Date 2023-SEPTEMBER-18

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements

MODEL INFO

33ATD

Automatic air/vacuum valve

MODEL 33ATD			
Inlet Size NPT (in)	Orifice Size (in)	Outlet Size NPT (in)	Rated Pressure (psig)
1	0.076	1	300
2	0.076	2	300
3	0.076	3	300
4	0.076	4	300
6	0.076	6	300

Deborah Jennings-Conner

Deborah Jennings-Conner, VP Regulatory Services

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

